



Green Valley County Water District 2023 Consumer Confidence Report

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2023

**Our only water source is from eight wells located throughout the valley.
Listed below is the location of sources:**

Well No. 2A - Calle Cascada	Well No. 7 - Calle Hermosa
Well No. 4 - Shoreline Drive	Well No. 9 - Calle Laguna
Well No. 5 - Calle Cascada (District Office)	Well No. 11 - Calle Berro
Well No. 6 - Calle Aqua Feliz	Well No. 12 - Pastel Walk

Drinking Water Source Assessment information:

The Green Valley County Water District conducted a Source Water Assessment Protection Program (SWAP) on our water system in October 2001 on all of the wells listed above. The goal of this program is to identify, develop and implement measures that advance the protection of our drinking water. Nitrates were detected in all the groundwater sources; however, no PCA (possible contaminating activities) has been determined responsible for the occurrence of this contaminant. Nevertheless, these sources are considered most vulnerable to the activity of high-density septic systems. A copy of this report is available at the District Office.

Time and place of regularly scheduled board meetings for public participation:

Our regularly scheduled meetings are held on the second Thursday of every month at 6:00 PM at the District office located at 39520 Calle Cascada, Green Valley, CA 91390.

For more information , please contact Kevin Francis 661-270-0836

Visit our WEBSITE: <http://gvcwd.org> - email: info@gvcwd.org.

We want our valued customers to be informed about their water utility.

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Primary Drinking Water Standards (PDWS): MCLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

pCi/L: picocuries per liter (a measure of radiation)

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Notification Level (NL) The concentration level of a contaminant in drinking water delivered for human consumption that the department has determined, based on available scientific information, does not pose a significant health risk but warrants notification pursuant to this section.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.



The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally occurring or be the result of oil and gas production and mining activities.
- *Total Coliform*: Water systems are required to meet a strict standard for coliform bacteria. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If the standard is exceeded, the water supplier must notify the public by newspaper, television or radio.

In order to ensure that tap water is safe to drink, USEPA and the State Water Resources Control Board, Division of Drinking Water (Division) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Division regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

The tables starting at the bottom of this page and continued on pages 3 and 4 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Division allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected. The Green Valley County Water District tests for over 200 drinking water contaminants, only the ones detected appear in the table on page 3.

We would like to thank all our customers that help us protect our water sources, which are the heart of our community, our way of life and our children's future.



Distribution System Samples							
Parameter	MCL (AL)	PHG (MCLG)	Units	Year Tested	Result	Violation	Major Sources In Drinking Water
Microbiological Contaminants							
Total Coliform Bacteria	2 or more positive samples per month	0	No. of positive samples per month	2023	4	No	Naturally present in the environment
Fecal Coliform and E.coli	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or E.coli positive	0	No. of positive sampler per year	2023	0	No	Human and animal fecal waste

Disinfectant Byproducts	Range	Average
-------------------------	-------	---------

Total Trihalomethanes (TTHMs)	80	N/A	ppb	2023	16-18	17	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	60	N/A	ppb	2023	0-7	3.5	
Chlorine Residual	MRDL=4.0	MRDLG=4.0	ppm	2023	0.37-1.05	0.71	Drinking water disinfectant added for treatment
Parameter	MCL	PHG	Units	Year	Range	Average	Major Sources in Drinking Water
	(AL)	(MCLG)		Tested			
Radioactive Contaminants							
Radium 228	2	0.019	pCi/L	2019	0.0-0.483	0.19	Radioactive decay of uranium and thorium in rocks and soil
Uranium	20	0.43	pCi/L	2019	0.446-1.450	0.71	Naturally occurring mineral
Gross Alpha particle activity	15	N/A	PCi/L	2021	0.94-2.71	1.73	Erosion of natural deposits
Inorganics							
Chromium (Total)	50	(100)	ppb	2022	10-24	16	Discharge from steel and pulp mills and chrome plating erosion of natural deposits
Barium	1000	0.2	ppb	2022	0-116	16.6	Discharge of oil drilling wastes and from metal refineries erosion of natural deposits
Fluoride	2	1	ppm	2022	0.5-0.7	0.6	water additive which promotes strong teeth, discharge from fertilizer and aluminum
Nitrate (as Nitrogen N)	10	10	ppm	2023	1.3-9.9	5.60	Runoff and leaching from fertilizer use; leaching from septic tanks and sew age; erosion of natural deposits
Vanadium	(50)	N/A	ppm	2005	3.0 - 3.0	5.75	The babies of some pregnant women who drink water containing vanadium in excess of the notification level may have an increased risk of developmental effects, based on studies in laboratory animals
Hexavalent	10	N/A	ppb	2014	ND	0	
Additional Constituents Analyzed (Groundwater Samples)							
Parameter	MCL	PHG	Units	Year	Range	Average	Major Sources in Drinking Water
	(NL)	(MCLG)		Tested			
pH	No Standard		Std units	2022	7.2-7.7	7.5	
Hardness	No Standard		mg/L	2022	266-304	290	
Sodium	No Standard		mg/L	2022	27-32	29.1	
Calcium	No Standard		mg/L	2022	62-72	67.7	
Potassium	No Standard		mg/L	2022	1-2	1.7	
Magnesium	No Standard		mg/L	2022	27-32	29.4	
Specific Conductance (E.C.)	1600		umho/cm	2022	654-712	665.4	Substances that form ions when in water; sewer
Total Alkalinity (as CaCO3)	No Standard		mg/L	2022	220-260	241.4	
Bicarbonate	No Standard		mg/L	2022	270-320	295.7	
Turbidity	TT	N/A		2022	0.0-0.5	0.1	Soil run off
Secondary Standards - Aesthetic Standard Established by the State Water Resources Control Board-Div of Drinking Water							
Aluminum	1000	0.6	ug/L	2022	ND	0	Erosion of natural deposits
Chloride	500		mg/L	2022	23-29	25.9	Runoff/leaching from natural deposits
Iron	300		ug/L	2022	ND	0	Leaching from natural deposits, industrial wastes
Lead	(15)	2	ug/L	2008	.2 - 2.5	0.83	
Apparent Color(Unfiltered)	15		units	2022	0-0.5	1.4	Naturally occurring organic materials
Mercury	2	1.2	ug/L	2022	ND	0	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills and cropland.
Sulfate	500		mg/L	2022	44.4-55.8	50.8	
Zinc	500		ug/L	2022	ND	0	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids	1000		mg/L	2022	370 - 420	388.6	Runoff/leaching from natural

***Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided on the next page.**

Lead and Copper Monitoring Program

Contaminant	AL = Action Level	No. of samples collected	Unit Measurement	Year Tested	90th percentile level detected	Number of samples that exceeded AL	Likely Source of Contamination
Lead (ppb)	15	10	ppb	2022	ND	0 of 10	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits; leaching from wood preservatives
Copper (ppb)	1300	10	ppb	2022	230	0 of 10	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Additional General Information on Drinking Water

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time may experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years may suffer liver or kidney damage. People with Wilson’s Disease should consult their personal doctor.

Lead: Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home’s plumbing. If you are concerned about elevated lead levels in your home’s water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the USEPA Safe Drinking Water Hotline (1-800-426-4791).

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Nitrate expressed as "nitrate as nitrogen" in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant’s blood to carry oxygen, resulting in serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate as nitrogen levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider. (Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity)

TTHMs [Total Trihalomethanes]: Some people who use water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems and may have an increased risk of getting cancer.



Green Valley County Water District
 39520 Calle Cascada, Green Valley, CA 91390
(661) 270-0836
 WEBSITE: <http://gvcwd.org>
 EMAIL: info@gvcwd.org
 OFFICE HOURS:
 Monday – Thursday
 8:00AM-4:00PM
 Regular Meetings of the Board of Directors are held on the
 2nd Thursday of every month at 6:00 PM at the District Office